

# UNICEF Weekly Report

Dis- trict	Allocation (m3)				Supplied (m3)							
	Daily Min	Daily Adj	Weekly Min	Weekly Adj	05 June	06 June	07 June	08 June	09 June	10 June	11 June	Actual
D1	242	280	1694	1960	268	270	239	306	273	292	279	1,927
D2	270	307	1890	2149	302	307	296	303	293	300	302	2,103
D3	179	208	1253	1456	207	201	208	202	198	203	203	1,422
D4	168	197	1176	1379	192	183	190	184	184	184	187	1,304
D5	206	242	1442	1694	217	233	239	225	241	233	238	1,626
D6	273	318	1911	2226	336	302	315	315	310	312	313	2,203
D7	253	299	1771	2093	292	273	292	286	282	298	299	2,022
D8	322	375	2254	2625	328	391	334	356	370	369	362	2,510
D9	195	223	1365	1561	207	215	223	211	216	212	220	1,504
D10	238	278	1666	1946	262	276	276	278	275	275	277	1,919
D11	302	349	2114	2443	351	328	380	354	368	312	363	2,456
D12	221	254	1547	1778	253	267	257	248	247	245	243	1,760
<b>Total</b>	2,869	3,330	20,083	23,310	3,215	3,246	3,249	3,268	3,257	3,235	3,286	22,756

Inside camp	Test	# / SOP	Fail	Resolved
	FRC	593/280	4	4
	Micro T	70/69	0	0

At gate	Test	# / SOP	Fail	Resolved
	Turbidity	702/413	1	1
	Ammonia	1/0	0	0
	pH	1/0	0	0
	TDS	466/0	0	0

Complaint Type	Count
Delayed delivery	14
Not enough water	3
Filling assumption not respected	1
Issue with water filler	0
Issue with CFP and water filler	0
Issue with CFP	4
Technical issue	1
<b>Grand Total</b>	<b>23</b>

Water supply was stable this week and close to the adjusted summer delivery, we only missed the daily minimum for one block by a few m3:  
7-6-2016: minimum = 242 / actual delivered = 239

Disinfection is ongoing in District11, we supply additional water to tanks that are disinfected.

Complaint Status	Count
Closed	22
Pending	1
<b>Grand Total</b>	<b>23</b>