

12/06/2016 - 18/06/2016

UNICEF Weekly Report

District	Allocation (m3)				Supplied (m3)							
	Daily Min	Daily Adj	Weekly Min	Weekly Adj	12 June	13 June	14 June	15 June	16 June	17 June	18 June	Actual
D1	242	280	1694	1960	283	271	280	271	276	283	272	1,936
D2	270	307	1890	2149	295	300	303	295	309	293	299	2,094
D3	179	208	1253	1456	203	200	210	194	204	199	197	1,407
D4	168	197	1176	1379	186	186	187	188	192	190	192	1,321
D5	206	242	1442	1694	236	237	245	237	241	246	245	1,687
D6	273	318	1911	2226	315	317	335	313	311	318	313	2,222
D7	253	299	1771	2093	286	294	289	284	298	288	285	2,024
D8	322	375	2254	2625	386	361	362	360	358	360	358	2,545
D9	195	223	1365	1561	225	214	217	216	210	223	219	1,524
D10	238	278	1666	1946	272	273	269	277	266	277	280	1,914
D11	302	349	2114	2443	358	330	356	368	344	356	339	2,451
D12	221	254	1547	1778	248	262	256	253	242	249	268	1,778
Total	2,869	3,330	20,083	23,310	3,293	3,245	3,309	3,256	3,251	3,282	3,267	22,903

Inside camp	Test	# / SOP	Fail	Resolved
	FRC	635/280	3	3
	Micro T	70/69	0	0

At gate	Test	# / SOP	Fail	Resolved
	Turbidity	705/413	0	0
	Ammonia	0/0	0	0
	pH	0/0	0	0
	TDS	445/0	0	0

Complaint Type	Count
Delayed delivery	18
Not enough water	0
Filling assumption not respected	0
Issue with water filler	1
Issue with CFP and water filler	0
Issue with CFP	1
Technical issue	1
Grand Total	21

Water supply was stable and all water was supplied by the internal boreholes. All daily deliveries to block level were above the minimum quantities and around the adjusted value.

Private tank disinfection moved from after finishing in District 11 to District 12

Complaint Status	Count
Closed	20
Pending	1
Grand Total	21