

19/06/2016 - 25/06/2016

UNICEF Weekly Report

District	Allocation (m3)				Supplied (m3)							
	Daily Min	Daily Adj	Weekly Min	Weekly Adj	12 June	13 June	14 June	15 June	16 June	17 June	18 June	Actual
D1	242	280	1694	1960	282	284	279	281	287	277	272	1962
D2	270	307	1890	2149	306	307	301	314	302	305	306	2141
D3	179	208	1253	1456	206	205	203	207	200	206	206	1433
D4	168	197	1176	1379	190	189	168	200	182	190	190	1309
D5	206	242	1442	1694	248	244	245	240	248	236	238	1699
D6	273	318	1911	2226	318	315	328	315	313	312	314	2215
D7	253	299	1771	2093	292	290	279	324	286	291	295	2057
D8	322	375	2254	2625	374	372	365	378	376	374	365	2604
D9	195	223	1365	1561	219	218	210	226	215	218	215	1521
D10	238	278	1666	1946	275	273	272	280	276	278	273	1927
D11	302	349	2114	2443	341	330	336	341	328	338	339	2353
D12	221	254	1547	1778	272	276	284	280	284	259	270	1925
Total	2869	3330	20083	23310	3323	3303	3270	3386	3297	3284	3283	23146

Inside camp	Test	# / SOP	Fail	Resolved
	FRC	545/280	0	0
	Micro T	71/69	0	0

At gate	Test	# / SOP	Fail	Resolved
	Turbidity	708/413	0	0
	Ammonia	1/0	0	0
	pH	1/0	0	0
	TDS	456/0	0	0

Water supply was stable and all water was supplied by the internal boreholes. All daily deliveries to block level where above the minimum quantities and around the adjusted value.

Complaint Type	Count
Delayed delivery	17
Not enough water	3
Filling assumption not respected	1
Issue with water filler	0
Issue with CFP and water filler	0
Issue with CFP	0
Technical issue	1
Grand Total	22

Complaint Status	Count
Closed	22
Pending	0
Grand Total	22